



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500002913

**Project :** PO#126993

21-September-2023

**PVNC Catholic DSB (Reg243 - Good Shepherd ES)**

Attn : Mwenu Amukun

**Date Rec. :** 18 September 2023

**LR Report:** CA14378-SEP23

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521  
Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	21-Sep-23
2: Analysis Start Time		---	06:45
3: Analysis Completed Date		---	21-Sep-23
4: Analysis Completed Time		---	12:49
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Hallway 127-BF	15-Sep-23 02:05	14.0	0.02
8: TAP Flushed - Hallway 127-BF	15-Sep-23 02:40	14.0	0.02

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury  
Project Specialist,  
Environment, Health & Safety