

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO

Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260014261 Project : PO#126993

15-September-2023

Date Rec.: 13 September 2023 LR Report: CA18202-SEP23

Copy: #1

PVNC Catholic DSB (Monsgr L Cleary-Courtice)

Attn: Mwenu Amukun

1355 Lansdowne Street West

Peterborough, ON K9J 7M3, Canada

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521

Fax:School Fax: 905-433-9933

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date				14-Sep-23	14-Sep-23
2: Analysis Start Time				13:26	13:26
3: Analysis Completed Date				15-Sep-23	15-Sep-23
4: Analysis Completed Time				12:53	12:53
5: MAC				0	0
6: DW DW-Room 154	13-Sep-23 13:50	11.0	0.19	0	0
7: RW RW-Utility Room	13-Sep-23 13:40	11.0		0	0

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code	
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001	
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001	

Kimberley Didsbury

Project Specialist,

Environment, Health & Safety