



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500002848

**Project :** PO#126993

14-September-2023

**PVNC Catholic DSB (Reg243 - Pope John Paul II ES)**

Attn : Mwenu Amukun

**Date Rec. :** 11 September 2023

**LR Report:** CA18067-SEP23

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521  
Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	14-Sep-23
2: Analysis Start Time		---	06:42
3: Analysis Completed Date		--	14-Sep-23
4: Analysis Completed Time		--	11:46
5: MAC		--	10
6: MDL		---	0.01
7: RESAMPLE TAP Standing - Hallway 153 Ftn	07-Sep-23 22:00	23.0	9.45
8: RESAMPLE TAP Flushed - Hallway 153 Ftn	07-Sep-23 22:35	23.0	4.57

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety