

**SGS Canada Inc.** P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO Phone: 705-652-2000 FAX: 705-652-6365

## **PVNC Catholic DSB (St Martins-Ennismore)**

Attn : Mwenu Amukun

1355 Lansdowne Street West Peterborough, ON K9J 7M3, Canada

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521 Fax:School Fax: 705-292-1915

## CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date				14-Sep-23	14-Sep-23
2: Analysis Start Time				16:05	16:05
3: Analysis Completed Date				15-Sep-23	15-Sep-23
4: Analysis Completed Time				15:40	15:40
5: MAC				0	0
6: DW DW - Staff Room	14-Sep-23 13:10	9.0	0.05	0	0
7: RW RW - Utility Room	14-Sep-23 13:20	9.0		0	0

MAC - Maximum Acceptable Concentration

## Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

letur)

Kimberley Didsbury Project Specialist, Environment, Health & Safety

OnLine LIMS

Results relate only to the sample tested. Data reported represents the sample submitted to SGS. Reproduction of this analytical report in full or in part is prohibited without prior written approval. Please refer to SGS General Conditions of Services located at https://www.sgs.ca/en/terms-and-conditions (Printed copies are available upon request.) Test method information available upon request. "Temperature Upon Receipt" is representative of the whole shipment and may not reflect the temperature of individual samples. SGS Canada Inc. Environment-Health & Safety statement of conformity decision rule does not consider uncertainty when analytical results are compared to a specified standard or regulation.

Works #: 260014313 Project : PO#126993

15-September-2023

Date Rec. : 14 September 2023 LR Report: CA16542-SEP23

**Copy:** #1

Page 1 of 1