



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500002861

Project : PO#126993

21-September-2023

PVNC Catholic DSB (Reg243 - St Mary's ES-Lindsay)

Attn : Mwenu Amukun

Date Rec. : 18 September 2023

LR Report: CA14389-SEP23

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	21-Sep-23
2: Analysis Start Time		---	06:45
3: Analysis Completed Date		---	21-Sep-23
4: Analysis Completed Time		---	12:51
5: MAC		---	10
6: MDL		---	0.01
7: RESAMPLE TAP Standing - Hallway 217-FTN	07-Sep-23 22:00	14.0	6.53
8: RESAMPLE TAP Flushed - Hallway 217-FTN	07-Sep-23 22:35	14.0	4.92

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety