



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038689

**Project :** PO#126993

02-October-2023

**PVNC Catholic DSB (Reg243 - Holy Family ES)**

Attn : Mwenu Amukun

**Date Rec. :** 26 September 2023

**LR Report:** CA14722-SEP23

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521  
Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	02-Oct-23
2: Analysis Start Time		---	08:36
3: Analysis Completed Date		--	02-Oct-23
4: Analysis Completed Time		--	12:21
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - Hallway 103-BF	21-Sep-23 03:11	9.0	0.33 RVNS
8: TAP Flushed - Hallway 103-BF	21-Sep-23 03:44	9.0	0.44 RVNS

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit  
RVNS - Required Volume Not Submitted for Lead under 0.Reg243/07.

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety