

P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO Phone: 705-652-2000 FAX: 705-652-6365 Works #: 500038702 Project : PO#126993

02-October-2023

PVNC Catholic DSB (Reg243 - Mother Teresa ES - Day Care)

Attn : Mwenu Amukun

Peterborough, ON K9J 7M3, Canada

1355 Lansdowne Street West

Date Rec. : 26 September 2023 LR Report: CA17024-SEP23

Copy: #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521 Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date			02-Oct-23
2: Analysis Start Time			08:36
3: Analysis Completed Date			02-Oct-23
4: Analysis Completed Time			12:42
5: MAC			10
6: MDL			0.01
7: TAP Standing - Daycare Infant Room 121-Tap	22-Sep-23 00:10	9.0	0.21
8: TAP Flushed - Daycare Infant Room 121-Tap	22-Sep-23 00:45	9.0	0.11

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

1	Parameter	Description	SGS Method Code
	Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury, Project Specialist, Environment, Health & Safety

0003486379

Page 1 of 1 Results relate only to the sample tested. Data reported represents the sample submitted to SGS. Reproduction of this analytical report in full or in part is prohibited without prior written approval. Please refer to SGS General Conditions of Services located at https://www.sgs.ca/en/terms-and-conditions (Printed copies are available upon request.) Test method information available upon request. "Temperature Upon Receipt" is representative of the whole shipment and may not reflect the temperature of individual samples. SGS Canada Inc. Environment-Health & Safety statement of conformity decision rule does not consider uncertainty when analytical results are compared to a specified standard or gravitation