



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 260096902

**Project :** PO#126993

16-October-2023

**PVNC Catholic DSB (St Josephs-Douro - Cistern System)**

Attn : Mwenu Amukun

**Date Rec. :** 12 October 2023

**LR Report:** CA17941-OCT23

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521  
Fax: School Fax: 705-652-8247

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date		---	12-Oct-23	12-Oct-23
2: Analysis Start Time		---	14:38	14:38
3: Analysis Completed Date		---	16-Oct-23	16-Oct-23
4: Analysis Completed Time		---	08:25	08:25
5: MAC		---	0	0
6: RNR RNR-Well Water	12-Oct-23 08:00	4.0	0	0

MAC - Maximum Acceptable Concentration  
RNR - Regulated Not Reportable

### Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury  
Project Specialist,  
Environment, Health & Safety