



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038676

Project : PO#126993

02-October-2023

PVNC Catholic DSB (Reg243 - St Joseph's ES-Bowmanville)

Attn : Mwenu Amukun

Date Rec. : 26 September 2023

LR Report: CA16905-SEP23

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	02-Oct-23
2: Analysis Start Time		---	08:36
3: Analysis Completed Date		---	02-Oct-23
4: Analysis Completed Time		---	12:25
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Hallway 177-BF	19-Sep-23 01:40	9.0	0.21
8: TAP Flushed - Hallway 177-BF	19-Sep-23 02:15	9.0	0.26

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety