



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260014313

Project : PO#126993

16-October-2023

PVNC Catholic DSB (St Martins-Ennismore)

Attn : Mwenu Amukun

Date Rec. : 12 October 2023

LR Report: CA17939-OCT23

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521
Fax: School Fax: 705-292-1915

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date		---	---	12-Oct-23	12-Oct-23
2: Analysis Start Time		---	---	14:38	14:38
3: Analysis Completed Date		---	---	16-Oct-23	16-Oct-23
4: Analysis Completed Time		---	---	08:25	08:25
5: MAC		---	---	0	0
6: DW DW-Staff Room	12-Oct-23 12:45	4.0	2.20	0	0
7: RW RW-Utility Room	12-Oct-23 12:55	4.0	---	2	0

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Hawley Anderson, Hon.B.Sc
Project Specialist,
Environment, Health & Safety