



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038871

Project : PO#126993

13-November-2023

PVNC Catholic DSB (Reg243 - St Paul's ES-Norwood)

Attn : Mwenu Amukun

Date Rec. : 10 November 2023

LR Report: CA16253-NOV23

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	13-Nov-23
2: Analysis Start Time		---	07:00
3: Analysis Completed Date		---	13-Nov-23
4: Analysis Completed Time		---	10:23
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - H-Library-BF	09-Nov-23 22:00	8.0	46.8 MAC
8: TAP Flushed - H-Library-BF	09-Nov-23 22:36	8.0	2.83

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety