

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO

Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500085151

Project : PO#126993

07-November-2023

Date Rec.: 28 October 2023 LR Report: CA18931-OCT23

Copy: #1

PVNC Catholic DSB (Reg243 - St Alphonsus ES-Daycare)

Attn : Mwenu Amukun

1355 Lansdowne Street West Peterborough, ON K9J 7M3, Canada

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521

Fax:

CERTIFICATE OF ANALYSIS Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Lead ug/L |
|-------------------------------------|-----------------------|-----------------------------------|--------------|
| 1: Analysis Start Date | | | 07-Nov-23 |
| 2: Analysis Start Time | | | 10:32 |
| 3: Analysis Completed Date | | | 07-Nov-23 |
| 4: Analysis Completed Time | | | 12:44 |
| 5: MAC | | | 10 |
| 6: MDL | | | 0.01 |
| 7: TAP Standing - Daycare 152 - Tap | 19-Oct-23 00:05 | 12.0 | 6.12 |
| 8: TAP Flushed - Daycare 152 - Tap | 19-Oct-23 00:40 | 12.0 | 1.79 |

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

| Parameter | Description | SGS Method Code |
|-----------|-------------------------------|---------------------------|
| Lead | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 |

Kimberley Didsbury, Project Specialist,

Environment, Health & Safety