



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500002887

Project : PO#126993

31-August-2023

PVNC Catholic DSB (Reg243 - St Michael's ES)

Attn : Mwenu Amukun

Date Rec. : 25 August 2023

LR Report: CA15153-AUG23

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	31-Aug-23
2: Analysis Start Time		---	09:44
3: Analysis Completed Date		--	31-Aug-23
4: Analysis Completed Time		--	13:00
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - H115-BF	23-Aug-23 23:36	22.0	6.87
8: TAP Flushed - H115-BF	24-Aug-23 00:11	22.0	3.06

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety