



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500035881

Project : PO#126993

01-November-2023

PVNC Catholic DSB (Reg243 - St Patrick's ES)

Attn : Mwenu Amukun

Date Rec. : 28 October 2023

LR Report: CA18930-OCT23

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Lead ug/L |
|-----------------------------------|--------------------|-----------------------------|-----------|
| 1: Analysis Start Date | | --- | 01-Nov-23 |
| 2: Analysis Start Time | | --- | 07:00 |
| 3: Analysis Completed Date | | --- | 01-Nov-23 |
| 4: Analysis Completed Time | | --- | 10:10 |
| 5: MAC | | --- | 10 |
| 6: MDL | | --- | 0.01 |
| 7: TAP Standing - Hallway 131-FTN | 18-Oct-23 23:10 | 12.0 | 0.26 |
| 8: TAP Flushed - Hallway 131-FTN | 18-Oct-23 23:45 | 12.0 | 0.47 |

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

| Parameter | Description | SGS Method Code |
|-----------|-------------------------------|---------------------------|
| Lead | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 |

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety