



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038741

**Project :** PO#126993

23-August-2024

**PVNC Catholic DSB (Reg243 - Msgr L Cleary ES)**

Attn : Nicole Teunissen

**Date Rec. :** 20 August 2024

**LR Report:** CA17193-AUG24

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 905-914-7130  
Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	23-Aug-24
2: Analysis Start Time		---	09:00
3: Analysis Completed Date		---	23-Aug-24
4: Analysis Completed Time		---	14:54
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Rm 116 - Tap	16-Aug-24 22:03	22.0	12.3 MAC
8: TAP Flushed - Rm 116 - Tap	16-Aug-24 22:39	22.0	4.76

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury  
Project Specialist,  
Environment, Health & Safety

