

SGS Canada Inc. P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO Phone: 705-652-2000 FAX: 705-652-6365

## PVNC Catholic DSB (Reg243 - St Mary's SS)

Attn : Nicole Teunissen

1355 Lansdowne Street West Peterborough, ON K9J 7M3, Canada

Phone: Office: 705-748-4861 Ext. 1286 Cell: 905-914-7130 Fax:

## CERTIFICATE OF ANALYSIS **Final Report**

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date			23-Aug-24
2: Analysis Start Time			09:00
3: Analysis Completed Date			23-Aug-24
4: Analysis Completed Time			15:17
5: MAC			10
6: MDL			0.01
7: TAP Standing - Hallway 124 - FTN (Left)	15-Aug-24 01:46	22.0	1.38
8: TAP Flushed - Hallway 124 - FTN (Left)	15-Aug-24 02:22	22.0	0.46

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

## Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury Project Specialist, Environment, Health & Safety

0003831828

**DhLine LIMS** 

Page 1 of 1 Results relate only to the sample tested. Data reported represents the sample submitted to SGS. Reproduction of this analytical report in full or in part is prohibited without prior written approval. Please refer to SGS General Conditions of Services located at https://www.sgs.ca/en/terms-and-conditions (Printed copies are available upon request.) Test method information available upon request. "Temperature Upon Receipt" is representative of the whole shipment and may not reflect the temperature of individual samples. SGS Canada Inc. Environment-Health & Safety statement of conformity decision rule does not consider uncertainty when analytical results are compared to a specified standard or

Works #: 500038793 Project : PO#126993

23-August-2024

Date Rec.: 20 August 2024 LR Report: CA17202-AUG24

Copy: #1

		<ul> <li>Lakeliela Job Curression St. Cakeliela, CW NCL 2nd Filiple. (Job 922-2000 Fab. Job 932-932-9305 Web WWW 59 contentionment - London 657 Consortium Court, London, ON, N6E 288 Phone. 519-672-4500 Toll Free. 877-848-8060 Fax. 519-672-0361</li> </ul>	0361	
Received By Sean burger	Received By (signature):	Laboratory Information Section - Lab use only	Temperature Upon Receipt °C 22	OX3 LABLIMS # AUGN 17202
Received Date: July 1201 24 (mm/dd/yy) Received Time: July 1201 (hr : min)	Cooling Agent Present Yes	No A Type MA	Laboratory Received Date:/	(mm/dd/yy) : min) Client ID#:
REPORT INFORMATION	INVOICE INFORMATION		WATER FACILITY INFORMATION	TURNAROUND TIME (TAT) REQUIRED
Company: Cambium Inc.	(same as Report Information)	System Name:	Peterborough Victoria Northumberand and Clarington CDSB (St. Mary's, Cobourg)	
Contact: Stew Dolstra	Company: PVNC Catholic DSB	Watenworks/DWS#: 500038793		TAT's are quoted in business days (exclude statutory holidays & weekends) Samples received after 6pm or on weekends: TAT begins next business day.
Address: 194 Sophia Street		Contact:	nc Stew Dolstra	Regular TAT (5-7days)
Peterborough ON K9H 1E5	Address: Peterborough, ON K9J 7M3	Contact Phone:	705-742-7900 ext 210 (StewD), or 705-740- 4378 (StewD - cell) 1050 Birchwood Trail Cohourg Ontario Kon	Rush TAT (1-4days)
Phone: 705-742-7900 ext 210 (Stew D)		Physical Address: 5S9, Can	5S9, Canada	
Fax:	Office: 705-748-4861 Ext. 1286 Cell: Phone: 416-770-5521		S	Specify Due Date:
Email: <u>Stew.Dolstra@cambium-inc.com</u>		Contact Fax: 705-742-7907	7907	
		Contact Email: Stew.Dol	Stew.Dolstra@cambium-inc.com	PLEASE CONFIRM RUSH FEASIBILITY WITH SGS REPRESENTATIVE PRIOR TO SUBMISSION (Additional Charges May Apply)
	P.O.#.	MOH Unit: Health Unit	Haliburton, Kawartha, Pine Ridge District Health Unit	
Project #:		Day Care License #/SFIS#: N/A		
As per the Ontario Safe Drinking Water Act and Health Pro these acts. The laboratory will report all adverse results as	tection and Promotion Act, the water facility inform, per the applicable regulation and source code.	ion and the sample information sections must be filled or	It prior to processing samples. Sample source c	As per the Ontario Safe Drinking Water Act and Health Protection and Promotion Act, the water facility information and the sample information sections must be filled out prior to processing samples. Sample source codes indicate whether samples are Reportable or Not Reportable under these acts. The laboratory will report all adverse results as per the applicable regulation and source code.
Please check regulation tha	Please check regulation that applies to water sample submitted	RW = Raw Water	Source water prior to treatment Water	Source water prior to treatment. Water is not for consumption
		TW = Treated Water	Water taken immediately afte	Water taken immediately after treatment at point of entry to the distribution system.
		DW = Distribution Water	Water taken from a distributic	Water taken from a distribution point in a system with treatment.
Certificate of Approval Requirement     Required Not Reportable (RNR)		DW-UT = Untreated Distribution Water		Raw water for consumption. Water taken from a distribution point in a system with no treatment (includes raw water from systems that have qualified for an exemption from treatment and raw water from systems that have a treatment existem that is not anonvect.
Required-Upload sample results in DWIS/LRMA	Not Required-Do not upload sample results in DWIS/LRMA	WIS/LRMA TAP (Standing & Flushed)	Water taken for the purposes	Water taken for the purposes of lead testing under O.Reg. 243/07 (Schools & Daycare)
Not Regulated (NR)		RNR = Regulated Not Reportable	Samples other that	taken from a non-standard location under the direction of the system owner for reasons n assessing water quality against the OSDWA.
		NR = Not Regulated Not Reportable	Samples	SDWA
Sample Information			ANALYSIS REQUESTED	UESTED
SAMPLE SOURCE SAMPLE IDENTIFICATION	ICATION DATE TIME SAMPLED SAMPLED	S-SAMPLE verse report	the analysis required below and check	please enter the analysis required below and check off which analysis applies to each sample Residual R
		from an Field Ti Residu	Lead	
1 TAP-Standing HAILWAY IDU - FTN (LCAY)	(Left) 08/5/2401:46	4	×	
2 TAP-Flushed Henning 124-FTN (Left)		2	×	
3 TAP-Standing				
4 TAP-Flushed				
5 TAP-Standing				
6 TAP-Flushed				
7 TAP-Standing				
8 TAP-Flushed				
9 TAP-Standing				
10 TAP-Flushed				
Observations/Comments/Special Instructions				
Sampled By (NAME): Ethon Martine	TC Signature:	EM	Date 08.	15,24 (mm/dd/yy)
VUN	ALTIC Signature:	en N	Date: 0% /	15-24
Date of Issue 20 Oct 2022 shipping documents). (3) Rosults m	have been the sent by email to an unlimited number of addresses for no additionation of addresses for no additionation of a set of the set of t	nal cost. Fax is available upon request. (4) Completion of work may require s	the story size considered additionization for completion of work. St the second standard between the London and Lakefold laboration	gnatures muy appear on this form or be retained on tile in the contract, or in an alternative format (e.g.